



TOSCANA

BAGNO LAURA

Viale del Tirreno 46 Tirrenia (Pi) – Telefono 050 30414

TESTED FOR YOU TO:



With the goal of putting at your disposal all relevant information to a conscious choice

Consult the following pages and find the information you need

Note The information below applies to the verification date on the bottom of each tab. The Association is not liable for any significant changes made by the hotel after the visit.

All text, information and photographic images contained in this document are the property of Handy Superabile and is therefore prohibited to use or reproduction, even partial, without the express consent of the author himself.



ARRIVAL AT THE STRUCTURE

The coast Pisano, which is part of TIRRENIA / MARINA DI PISA / CALAMBRONE is a lying coastal land between the Versilia and the port of Livorno, with a long beach of fine sand. The main avenue, which runs alongside the beautiful pine forest, gives access to the bathing establishments. Most of the baths has a chair JOB, for bathing the disabled, but there is the possibility of requesting a the City of Pisa, or the association Handy Superabile.

FROM THE MAIN ENTRANCE PARKING





The plant is equipped with a private car park which has 2 reserved parking spaces for disabled people marked with road markings and / or vertical.

The public car park is located along the coastal road and generally has 1 car, every 50, reserved for the handicapped, highlighted with road markings and / or vertical. However, people with disabilities, special badge holders can park their car for free even in blue stalls. In public outdoor parking and private indoor flooring is asphalt.

The entrance is accessible by ramp: length. 100 cm, width. > 100 cm, gradient 15%. There are tactile indicators and / or tactile maps of orientation for the blind / visually impaired. The door / entry gate has a clear width exceeding 90 cm.








BAR/RESTAURANT





The bar / self service restaurant is accessible by ramp: 80 cm difference in height, length. 1500 cm, width. 350 cm, gradient 15%.

The useful width of the front door is more than 90 cm.

The bench of the bar has a depressed part (<100 cm) and the buffet counter (self-service) is 70 cm high from the ground.

The tables are to 4 stems with the useful height under the table to approach a 75 cm wheelchair. The restaurant has available the following gluten-free foods for celiac guests: biscuits, bread

Notes

it is recommended the customer with food allergies to report their needs when booking the restaurant.





ROUTES AND INDOOR COMMON SERVICES

LOCAL TOILET usable by GUESTS WITH MOBILITY 'REDUCED





There are n. 1 toilets accessible / usable by people with reduced mobility. The toilets are within a plan.

The useful width of the bathroom door is greater than 90 cm.

The height of the toilet is 50 cm and the seat has open front, with the handle on the left of the toilet. And 'it presents a flexible shower head in the toilet side.



Free space to the right of the toilet more than 100 cm, 30 cm to the left of the toilet and the toilet front of more than 100 cm.

It 'a string electric bell. Height under the sink for wheelchair approach 85 cm, without mirror usable by a customer in a wheelchair.

The shower is shared with the local toilet.

The shower tray is flush with the floor. The shower is equipped with plastic chair.

There is not a support handle and from a sitting position you can reach the faucet. To the side is a string electric bell.

The toilets have cold showers 7 and 8 hot showers. In the toilets of the ladies it is available to an area with a baby changing table.



BEACH





The beach is accessible by plane.

On the beach there is a walkway, PVC, 100 cm wide leading down to the 1st row of umbrellas.

And 'possible to reserve to the customer in a wheelchair with limited mobility / blind the umbrella with deck adjacent to the walkway.

There is not a footboard / extension of PVC or wood, also removable, between the catwalk and cot to facilitate the transition and the stationing of the wheelchair.

The establishment has one special amphibious chair for bathing of persons with physical disabilities, such as JOB, and the staff is available to offer assistance for disabled people to transport using the same water, and vice versa

